



COMPONENT SPECIALISTS

P.O. Box 500
 899 S. Prairie Lane
 Marshfield, MO 65706
 Phone: (417)859-6067
 Fax: (417)859-2109

Model: HITACHI 4005SC-Z

CAPACITY -1,000 BTU/Hr, 60 Hz. HITACHI 4005 COMPRESSOR, REFRIGERANT 22

SCT → SST	77	81	85	89	93	97	101	105	109	113	117	121	125	129	133	137	141	145
5	317.1	312.6	307.2	300.9	293.8	286.1	277.9	269.3	260.4	251.2	242.0	232.8	223.7	214.9	206.4	198.4	191.0	184.3
10	362.2	354.5	346.4	337.9	329.0	319.8	310.4	300.9	291.3	281.6	272.0	262.5	253.1	243.9	235.1	226.6	218.5	210.9
15	407.9	398.3	388.4	378.2	367.9	357.5	347.0	336.4	325.9	315.4	305.0	294.7	284.6	274.8	265.2	255.9	247.0	238.5
20	455.1	444.3	433.3	422.1	410.7	399.1	387.5	375.9	364.3	352.7	341.3	330.0	318.9	308.0	297.4	287.2	277.4	267.9
25	504.5	493.2	481.5	469.5	457.2	444.7	432.1	419.3	406.6	393.8	381.2	368.6	356.3	344.3	332.5	321.1	310.2	299.7
30	556.9	545.4	533.2	520.6	507.6	494.2	480.6	466.7	452.8	438.8	424.9	411.1	397.5	384.1	371.0	358.4	346.2	334.6
31	567.9	556.2	544.0	531.3	518.1	504.5	490.7	476.7	462.6	448.3	434.2	420.1	406.2	392.5	379.2	366.3	353.9	342.0
32	578.9	567.2	554.9	542.1	528.8	515.1	501.1	486.8	472.5	458.0	443.6	429.2	415.1	401.2	387.6	374.4	361.7	349.6
33	590.1	578.4	566.0	553.1	539.6	525.7	511.6	497.1	482.5	467.8	453.2	438.6	424.1	410.0	396.1	382.7	369.7	357.3
34	601.5	589.8	577.3	564.2	550.6	536.6	522.2	507.6	492.8	477.8	462.9	448.1	433.4	418.9	404.8	391.1	377.9	365.3
35	613.1	601.3	588.7	575.5	561.8	547.6	533.0	518.2	503.2	488.0	472.9	457.8	442.8	428.1	413.7	399.7	386.2	373.3
36	624.9	612.9	600.3	586.9	573.1	558.7	544.0	529.0	513.7	498.4	483.0	467.7	452.5	437.5	422.8	408.6	394.8	381.6
37	636.8	624.8	612.0	598.5	584.5	570.0	555.1	539.9	524.5	508.9	493.3	477.7	462.3	447.0	432.1	417.6	403.5	390.0
38	649.0	636.8	623.9	610.3	596.1	581.5	566.4	551.0	535.4	519.6	503.8	488.0	472.3	456.8	441.6	426.8	412.5	398.7
39	---	649.0	635.9	622.2	607.9	593.1	577.8	562.3	546.4	530.5	514.4	498.4	482.5	466.8	451.3	436.2	421.6	407.5
40	---	661.4	648.2	634.3	619.8	604.8	589.4	573.7	557.7	541.5	525.3	509.1	492.9	477.0	461.3	445.9	431.0	416.5
41	---	674.0	660.6	646.5	631.9	616.7	601.2	585.3	569.1	552.8	536.3	519.9	503.6	487.4	471.4	455.8	440.5	425.8
42	---	686.7	673.2	658.9	644.1	628.8	613.1	597.0	580.7	564.2	547.6	531.0	514.4	498.0	481.8	465.9	450.3	435.2
43	---	699.7	685.9	671.5	656.5	641.0	625.1	608.9	592.5	575.8	559.0	542.2	525.5	508.8	492.4	476.2	460.3	444.9
44	---	712.9	698.8	684.2	669.0	653.4	637.4	621.0	604.4	587.6	570.7	553.7	536.8	519.9	503.2	486.8	470.6	454.8
45	---	---	711.9	697.1	681.7	665.9	649.7	633.2	616.5	599.6	582.5	565.4	548.3	531.2	514.3	497.6	481.1	464.9
46	---	---	725.2	710.1	694.6	678.6	662.3	645.6	628.8	611.7	594.5	577.3	560.0	542.8	525.6	508.6	491.8	475.3
47	---	---	738.7	723.4	707.6	691.4	675.0	658.2	641.2	624.1	606.8	589.4	572.0	554.6	537.2	519.9	502.8	485.9
48	---	---	752.4	736.7	720.7	704.4	687.8	670.9	653.9	636.6	619.2	601.8	584.2	566.6	549.0	531.5	514.1	496.7
49	---	---	766.2	750.3	734.1	717.6	700.8	683.8	666.7	649.4	631.9	614.3	596.7	578.9	561.2	543.4	525.6	507.8
50	---	---	780.3	764.0	747.5	730.8	714.0	696.9	679.7	662.3	644.8	627.1	609.4	591.5	573.5	555.5	537.4	519.2

Legend: SCT = Saturated Condensing Temperature, R-22.
 SST = Saturated Suction Temperature, R-22.

- Notes: 1. Data subject to a +/- 5% tolerance.
 2. Data based on 9 degrees Fahrenheit Subcooling & Superheat.
 3. - - - indicates conditions outside of the approved operating range.
 4. Operation outside the range of 14-46 deg F SST or 95-130 SCT is limited.
 See ACCS publication **AC- 02- 006- 01- 0051** for details.



COMPONENT SPECIALISTS

P.O. Box 500
 899 S. Prairie Lane
 Marshfield, MO 65706
 Phone: (417)859-6067
 Fax: (417)859-2109

Model: HITACHI 4005SC-Z

AMPS -208V/3/60 Hz. HITACHI 4005 COMPRESSOR, REFRIGERANT 22

SCT →	77	81	85	89	93	97	101	105	109	113	117	121	125	129	133	137	141	145
SST																		
5	62.8	68.4	74.0	79.5	85.1	90.7	96.3	101.8	107.4	113.0	118.6	124.1	129.7	135.3	140.9	146.5	152.0	157.6
10	64.0	70.0	75.8	81.6	87.4	93.1	98.7	104.4	109.9	115.5	121.0	126.5	132.0	137.5	143.0	148.5	154.0	159.5
15	65.3	71.6	77.8	83.8	89.8	95.6	101.3	106.9	112.5	118.0	123.5	129.0	134.4	139.9	145.3	150.8	156.3	161.8
20	66.6	73.3	79.8	86.0	92.1	98.1	103.9	109.6	115.2	120.7	126.1	131.6	137.0	142.4	147.8	153.3	158.9	164.6
25	67.8	74.9	81.7	88.2	94.5	100.6	106.5	112.2	117.8	123.4	128.8	134.2	139.7	145.1	150.6	156.1	161.8	167.6
30	69.1	76.5	83.6	90.3	96.8	103.0	109.0	114.9	120.6	126.1	131.6	137.1	142.5	148.0	153.5	159.1	164.8	170.7
31	69.3	76.8	83.9	90.7	97.2	103.5	109.5	115.4	121.1	126.7	132.2	137.7	143.1	148.6	154.1	159.7	165.4	171.3
32	69.5	77.1	84.3	91.1	97.7	104.0	110.1	115.9	121.7	127.3	132.8	138.2	143.7	149.2	154.7	160.3	166.1	172.0
33	69.8	77.4	84.6	91.5	98.1	104.5	110.6	116.5	122.2	127.8	133.4	138.8	144.3	149.8	155.3	160.9	166.7	172.6
34	70.0	77.7	85.0	91.9	98.6	104.9	111.0	117.0	122.7	128.4	133.9	139.4	144.9	150.4	155.9	161.6	167.3	173.2
35	70.3	78.0	85.3	92.3	99.0	105.4	111.5	117.5	123.3	129.0	134.5	140.0	145.5	151.0	156.6	162.2	167.9	173.8
36	70.5	78.3	85.7	92.7	99.4	105.8	112.0	118.0	123.9	129.5	135.1	140.7	146.1	151.7	157.2	162.8	168.5	174.4
37	70.8	78.6	86.0	93.1	99.8	106.3	112.5	118.5	124.4	130.1	135.7	141.3	146.8	152.3	157.8	163.5	169.2	175.0
38	71.0	78.9	86.3	93.4	100.2	106.7	113.0	119.1	125.0	130.7	136.3	141.9	147.4	152.9	158.5	164.1	169.8	175.6
39	---	79.1	86.6	93.8	100.6	107.2	113.5	119.6	125.5	131.3	136.9	142.5	148.1	153.6	159.1	164.7	170.4	176.2
40	---	79.4	86.9	94.1	101.0	107.6	113.9	120.1	126.1	131.9	137.6	143.2	148.7	154.3	159.8	165.4	171.0	176.8
41	---	79.7	87.2	94.5	101.4	108.0	114.4	120.6	126.6	132.5	138.2	143.8	149.4	154.9	160.5	166.0	171.6	177.3
42	---	79.9	87.5	94.8	101.7	108.4	114.9	121.1	127.2	133.1	138.8	144.5	150.1	155.6	161.1	166.7	172.2	177.9
43	---	80.2	87.8	95.1	102.1	108.8	115.3	121.6	127.7	133.6	139.4	145.1	150.7	156.3	161.8	167.3	172.8	178.4
44	---	80.4	88.1	95.4	102.4	109.2	115.8	122.1	128.3	134.2	140.1	145.8	151.4	157.0	162.5	168.0	173.4	178.9
45	---	---	88.3	95.7	102.8	109.6	116.2	122.6	128.8	134.8	140.7	146.5	152.1	157.7	163.2	168.6	174.0	179.4
46	---	---	88.6	96.0	103.1	110.0	116.7	123.1	129.4	135.5	141.4	147.2	152.8	158.4	163.9	169.3	174.6	179.9
47	---	---	88.8	96.3	103.4	110.4	117.1	123.6	129.9	136.1	142.0	147.9	153.5	159.1	164.6	169.9	175.2	180.4
48	---	---	89.1	96.5	103.7	110.7	117.5	124.1	130.5	136.7	142.7	148.6	154.3	159.8	165.3	170.6	175.7	180.8
49	---	---	89.3	96.8	104.0	111.1	117.9	124.6	131.0	137.3	143.4	149.3	155.0	160.6	166.0	171.2	176.3	181.2
50	---	---	89.5	97.0	104.3	111.4	118.3	125.1	131.6	137.9	144.0	150.0	155.7	161.3	166.7	171.8	176.8	181.7

Legend: SCT = Saturated Condensing Temperature, R-22.
 SST = Saturated Suction Temperature, R-22.

- Notes: 1. Data subject to a +/- 5% tolerance.
 2. Data based on 9 degrees Fahrenheit Subcooling & Superheat.
 3. - - - indicates conditions outside of the approved operating range.
 4. Operation outside the range of 14-46 deg F SST or 95-130 SCT is limited.
 See ACCS publication **AC- 02- 006- 01- 0051** for details.



COMPONENT SPECIALISTS

P.O. Box 500
 899 S. Prairie Lane
 Marshfield, MO 65706
 Phone: (417)859-6067
 Fax: (417)859-2109

Model: HITACHI 4005SC-Z

AMPS -230V/3/60 Hz. HITACHI 4005 COMPRESSOR, REFRIGERANT 22

SCT →	77	81	85	89	93	97	101	105	109	113	117	121	125	129	133	137	141	145
SST																		
5	64.6	69.6	74.6	79.5	84.4	89.3	94.2	99.1	103.9	108.7	113.5	118.3	123.0	127.7	132.4	137.1	141.7	146.4
10	68.9	73.5	78.1	82.7	87.4	92.1	96.8	101.6	106.3	111.1	115.9	120.7	125.6	130.5	135.4	140.3	145.3	150.3
15	72.0	76.4	80.8	85.3	89.8	94.4	99.1	103.8	108.5	113.3	118.1	123.0	128.0	133.0	138.0	143.1	148.3	153.5
20	74.3	78.6	83.0	87.4	91.9	96.5	101.1	105.8	110.5	115.4	120.2	125.2	130.2	135.3	140.4	145.6	150.9	156.3
25	75.9	80.3	84.7	89.1	93.7	98.3	103.0	107.7	112.5	117.4	122.3	127.4	132.4	137.6	142.8	148.1	153.5	158.9
30	77.3	81.7	86.2	90.7	95.3	100.0	104.8	109.6	114.5	119.5	124.5	129.6	134.8	140.1	145.4	150.8	156.2	161.8
31	77.5	82.0	86.5	91.0	95.7	100.4	105.2	110.0	114.9	119.9	125.0	130.1	135.3	140.6	145.9	151.3	156.8	162.4
32	77.8	82.2	86.8	91.3	96.0	100.7	105.5	110.4	115.3	120.3	125.4	130.6	135.8	141.1	146.5	151.9	157.4	163.0
33	78.1	82.5	87.1	91.7	96.3	101.1	105.9	110.8	115.8	120.8	125.9	131.1	136.3	141.6	147.0	152.5	158.0	163.6
34	78.3	82.8	87.4	92.0	96.7	101.4	106.3	111.2	116.2	121.3	126.4	131.6	136.9	142.2	147.6	153.1	158.7	164.3
35	78.6	83.1	87.7	92.3	97.0	101.8	106.7	111.6	116.6	121.7	126.9	132.1	137.4	142.8	148.2	153.8	159.4	165.0
36	78.9	83.4	88.0	92.6	97.4	102.2	107.1	112.0	117.1	122.2	127.4	132.6	138.0	143.4	148.9	154.4	160.0	165.8
37	79.2	83.7	88.3	93.0	97.7	102.6	107.5	112.5	117.5	122.7	127.9	133.2	138.5	144.0	149.5	155.1	160.8	166.5
38	79.5	84.0	88.6	93.3	98.1	103.0	107.9	112.9	118.0	123.2	128.4	133.7	139.1	144.6	150.2	155.8	161.5	167.3
39	---	84.4	89.0	93.7	98.5	103.4	108.3	113.4	118.5	123.7	128.9	134.3	139.7	145.3	150.9	156.5	162.3	168.1
40	---	84.7	89.3	94.1	98.9	103.8	108.8	113.8	119.0	124.2	129.5	134.9	140.4	145.9	151.6	157.3	163.1	169.0
41	---	85.1	89.7	94.5	99.3	104.2	109.2	114.3	119.5	124.7	130.1	135.5	141.0	146.6	152.3	158.1	164.0	169.9
42	---	85.5	90.1	94.9	99.7	104.6	109.7	114.8	120.0	125.3	130.6	136.1	141.7	147.3	153.1	158.9	164.9	170.9
43	---	85.9	90.5	95.3	100.1	105.1	110.1	115.3	120.5	125.8	131.2	136.8	142.4	148.1	153.9	159.8	165.8	171.9
44	---	86.3	91.0	95.7	100.6	105.5	110.6	115.8	121.0	126.4	131.9	137.4	143.1	148.8	154.7	160.7	166.7	172.9
45	---	---	91.4	96.2	101.0	106.0	111.1	116.3	121.6	127.0	132.5	138.1	143.8	149.6	155.6	161.6	167.8	174.0
46	---	---	91.9	96.7	101.5	106.5	111.6	116.8	122.1	127.6	133.1	138.8	144.6	150.5	156.5	162.6	168.8	175.1
47	---	---	92.4	97.2	102.0	107.0	112.1	117.4	122.7	128.2	133.8	139.5	145.4	151.3	157.4	163.6	169.9	176.3
48	---	---	92.9	97.7	102.6	107.6	112.7	117.9	123.3	128.9	134.5	140.3	146.2	152.2	158.4	164.6	171.1	177.6
49	---	---	93.5	98.2	103.1	108.1	113.3	118.5	124.0	129.5	135.2	141.0	147.0	153.1	159.4	165.7	172.3	178.9
50	---	---	94.1	98.8	103.7	108.7	113.8	119.1	124.6	130.2	135.9	141.8	147.9	154.1	160.4	166.9	173.5	180.3

Legend: SCT = Saturated Condensing Temperature, R-22.
 SST = Saturated Suction Temperature, R-22.

- Notes:
1. Data subject to a +/- 5% tolerance.
 2. Data based on 9 degrees Fahrenheit Subcooling & Superheat.
 3. - - - indicates conditions outside of the approved operating range.
 4. Operation outside the range of 14-46 deg F SST or 95-130 SCT is limited.
 See ACCS publication **AC- 02- 006- 01- 0051** for details.



COMPONENT SPECIALISTS

P.O. Box 500
 899 S. Prairie Lane
 Marshfield, MO 65706
 Phone: (417)859-6067
 Fax: (417)859-2109

Model: HITACHI 4005SC-Z

AMPS -460V/3/60 Hz. HITACHI 4005 COMPRESSOR, REFRIGERANT 22

SCT →	77	81	85	89	93	97	101	105	109	113	117	121	125	129	133	137	141	145
SST																		
5	32.5	34.9	37.3	39.6	41.9	44.2	46.4	48.7	51.0	53.3	55.7	58.2	60.7	63.3	66.0	68.7	71.7	74.7
10	33.0	35.5	38.0	40.4	42.8	45.1	47.4	49.8	52.1	54.5	56.9	59.3	61.9	64.5	67.2	70.0	72.9	75.9
15	33.6	36.2	38.8	41.2	43.7	46.1	48.5	50.8	53.2	55.6	58.1	60.6	63.1	65.8	68.5	71.3	74.2	77.3
20	34.3	37.0	39.6	42.1	44.6	47.1	49.5	52.0	54.4	56.9	59.3	61.9	64.5	67.1	69.9	72.7	75.6	78.7
25	35.0	37.7	40.4	43.0	45.6	48.1	50.6	53.1	55.6	58.1	60.6	63.2	65.8	68.5	71.3	74.1	77.1	80.2
30	35.7	38.5	41.3	43.9	46.5	49.1	51.7	54.2	56.7	59.3	61.8	64.4	67.1	69.8	72.7	75.6	78.6	81.7
31	35.9	38.7	41.4	44.1	46.7	49.3	51.9	54.4	56.9	59.5	62.1	64.7	67.4	70.1	72.9	75.8	78.9	82.0
32	36.0	38.9	41.6	44.3	46.9	49.5	52.1	54.6	57.2	59.7	62.3	64.9	67.6	70.4	73.2	76.1	79.2	82.3
33	36.2	39.0	41.8	44.5	47.1	49.7	52.3	54.8	57.4	60.0	62.6	65.2	67.9	70.6	73.5	76.4	79.4	82.6
34	36.3	39.2	42.0	44.7	47.3	49.9	52.5	55.1	57.6	60.2	62.8	65.4	68.1	70.9	73.7	76.7	79.7	82.9
35	36.5	39.4	42.1	44.9	47.5	50.1	52.7	55.3	57.8	60.4	63.0	65.7	68.4	71.1	74.0	76.9	80.0	83.2
36	36.6	39.5	42.3	45.0	47.7	50.3	52.9	55.5	58.1	60.7	63.3	65.9	68.6	71.4	74.3	77.2	80.3	83.5
37	36.8	39.7	42.5	45.2	47.9	50.5	53.1	55.7	58.3	60.9	63.5	66.2	68.9	71.7	74.5	77.5	80.5	83.7
38	37.0	39.9	42.7	45.4	48.1	50.7	53.3	55.9	58.5	61.1	63.7	66.4	69.1	71.9	74.8	77.7	80.8	84.0
39	---	40.0	42.8	45.6	48.3	50.9	53.5	56.1	58.7	61.3	64.0	66.6	69.4	72.1	75.0	78.0	81.1	84.3
40	---	40.2	43.0	45.8	48.5	51.1	53.7	56.3	58.9	61.5	64.2	66.9	69.6	72.4	75.3	78.2	81.3	84.5
41	---	40.4	43.2	46.0	48.7	51.3	53.9	56.5	59.1	61.8	64.4	67.1	69.8	72.6	75.5	78.5	81.6	84.8
42	---	40.5	43.4	46.1	48.9	51.5	54.1	56.8	59.4	62.0	64.6	67.3	70.0	72.8	75.7	78.7	81.8	85.0
43	---	40.7	43.6	46.3	49.0	51.7	54.3	57.0	59.6	62.2	64.8	67.5	70.3	73.1	76.0	78.9	82.0	85.2
44	---	40.9	43.7	46.5	49.2	51.9	54.5	57.2	59.8	62.4	65.0	67.7	70.5	73.3	76.2	79.2	82.3	85.5
45	---	---	43.9	46.7	49.4	52.1	54.7	57.4	60.0	62.6	65.3	67.9	70.7	73.5	76.4	79.4	82.5	85.7
46	---	---	44.1	46.9	49.6	52.3	54.9	57.6	60.2	62.8	65.5	68.2	70.9	73.7	76.6	79.6	82.7	85.9
47	---	---	44.3	47.1	49.8	52.5	55.1	57.7	60.4	63.0	65.7	68.4	71.1	73.9	76.8	79.8	82.9	86.1
48	---	---	44.5	47.2	50.0	52.7	55.3	57.9	60.6	63.2	65.9	68.5	71.3	74.1	77.0	80.0	83.1	86.3
49	---	---	44.6	47.4	50.2	52.8	55.5	58.1	60.8	63.4	66.0	68.7	71.5	74.3	77.2	80.2	83.3	86.5
50	---	---	44.8	47.6	50.3	53.0	55.7	58.3	60.9	63.6	66.2	68.9	71.7	74.5	77.4	80.4	83.4	86.7

Legend: SCT = Saturated Condensing Temperature, R-22.
 SST = Saturated Suction Temperature, R-22.

- Notes: 1. Data subject to a +/- 5% tolerance.
 2. Data based on 9 degrees Fahrenheit Subcooling & Superheat.
 3. - - - indicates conditions outside of the approved operating range.
 4. Operation outside the range of 14-46 deg F SST or 95-130 SCT is limited.
 See ACCS publication **AC- 02- 006- 01- 0051** for details.



COMPONENT SPECIALISTS

P.O. Box 500
 899 S. Prairie Lane
 Marshfield, MO 65706
 Phone: (417)859-6067
 Fax: (417)859-2109

Model: HITACHI 4005SC-Z

KILOWATTS - 60 Hz. HITACHI 4005 COMPRESSOR, REFRIGERANT 22

SCT → SST	77	81	85	89	93	97	101	105	109	113	117	121	125	129	133	137	141	145
5	20.8	22.5	24.2	25.9	27.6	29.3	31.1	32.8	34.6	36.5	38.4	40.3	42.3	44.4	46.6	48.8	51.2	53.6
10	21.4	23.1	24.9	26.6	28.4	30.1	31.9	33.7	35.5	37.3	39.2	41.2	43.2	45.3	47.5	49.7	52.1	54.5
15	21.9	23.8	25.6	27.4	29.1	30.9	32.7	34.5	36.4	38.3	40.2	42.1	44.2	46.3	48.4	50.7	53.0	55.4
20	22.5	24.4	26.3	28.1	29.9	31.8	33.6	35.5	37.3	39.2	41.2	43.2	45.2	47.3	49.4	51.7	54.0	56.4
25	23.1	25.0	27.0	28.9	30.8	32.6	34.5	36.4	38.3	40.2	42.2	44.2	46.2	48.3	50.4	52.6	54.9	57.3
30	23.6	25.6	27.7	29.6	31.6	33.5	35.4	37.4	39.3	41.3	43.2	45.2	47.3	49.3	51.5	53.6	55.9	58.2
31	23.7	25.8	27.8	29.8	31.7	33.7	35.6	37.6	39.5	41.4	43.4	45.4	47.5	49.5	51.7	53.8	56.1	58.4
32	23.8	25.9	27.9	29.9	31.9	33.9	35.8	37.7	39.7	41.6	43.6	45.6	47.7	49.7	51.9	54.0	56.3	58.6
33	23.9	26.0	28.1	30.1	32.1	34.0	36.0	37.9	39.9	41.8	43.8	45.8	47.9	49.9	52.1	54.2	56.5	58.8
34	24.1	26.2	28.2	30.2	32.2	34.2	36.2	38.1	40.1	42.0	44.0	46.0	48.1	50.1	52.3	54.4	56.7	59.0
35	24.2	26.3	28.3	30.4	32.4	34.4	36.3	38.3	40.3	42.2	44.2	46.2	48.3	50.3	52.5	54.6	56.9	59.2
36	24.3	26.4	28.5	30.5	32.5	34.5	36.5	38.5	40.4	42.4	44.4	46.4	48.5	50.5	52.7	54.8	57.1	59.4
37	24.4	26.5	28.6	30.7	32.7	34.7	36.7	38.7	40.6	42.6	44.6	46.6	48.7	50.7	52.9	55.0	57.3	59.5
38	24.5	26.6	28.8	30.8	32.9	34.9	36.9	38.8	40.8	42.8	44.8	46.8	48.9	50.9	53.1	55.2	57.4	59.7
39	---	26.8	28.9	31.0	33.0	35.0	37.0	39.0	41.0	43.0	45.0	47.0	49.1	51.1	53.2	55.4	57.6	59.9
40	---	26.9	29.0	31.1	33.2	35.2	37.2	39.2	41.2	43.2	45.2	47.2	49.2	51.3	53.4	55.6	57.8	60.1
41	---	27.0	29.2	31.2	33.3	35.3	37.3	39.4	41.3	43.3	45.4	47.4	49.4	51.5	53.6	55.8	58.0	60.3
42	---	27.1	29.3	31.4	33.4	35.5	37.5	39.5	41.5	43.5	45.5	47.6	49.6	51.7	53.8	56.0	58.2	60.5
43	---	27.3	29.4	31.5	33.6	35.6	37.7	39.7	41.7	43.7	45.7	47.7	49.8	51.9	54.0	56.2	58.4	60.6
44	---	27.4	29.5	31.7	33.7	35.8	37.8	39.8	41.9	43.9	45.9	47.9	50.0	52.1	54.2	56.3	58.6	60.8
45	---	---	29.7	31.8	33.9	35.9	38.0	40.0	42.0	44.0	46.1	48.1	50.2	52.2	54.4	56.5	58.7	61.0
46	---	---	29.8	31.9	34.0	36.1	38.1	40.1	42.2	44.2	46.2	48.3	50.3	52.4	54.5	56.7	58.9	61.2
47	---	---	29.9	32.1	34.2	36.2	38.3	40.3	42.3	44.3	46.4	48.4	50.5	52.6	54.7	56.9	59.1	61.4
48	---	---	30.0	32.2	34.3	36.4	38.4	40.4	42.5	44.5	46.5	48.6	50.7	52.8	54.9	57.1	59.3	61.6
49	---	---	30.2	32.3	34.4	36.5	38.5	40.6	42.6	44.7	46.7	48.7	50.8	52.9	55.1	57.2	59.5	61.7
50	---	---	30.3	32.4	34.5	36.6	38.7	40.7	42.8	44.8	46.8	48.9	51.0	53.1	55.2	57.4	59.6	61.9

Legend: SCT = Saturated Condensing Temperature, R-22.
 SST = Saturated Suction Temperature, R-22.

- Notes:
1. Data subject to a +/- 5% tolerance.
 2. Data based on 9 degrees Fahrenheit Subcooling & Superheat.
 3. - - - indicates conditions outside of the approved operating range.
 4. Operation outside the range of 14-46 deg F SST or 95-130 SCT is limited.
 See ACCS publication **AC- 02- 006- 01- 0051** for details.